

Test Results



Manufacturer	Spitzen Energy Solutions (India) Pvt. Ltd
Model	MONTANA
Reference Power at 11 m/s	3100 W
Reference Annual Energy at 5 m/s average wind speed, actual production will vary depending on site conditions	6634 kWh
Declared Sound Power at 8 m/s	Not Measured
Turbine Test Class (I-IV or S for Special)	Class III
Tested by	National Institute of Wind Energy
Published Date (Year-Month-Day)	05.11.2016

For more information, see

niwe.res.in